




19020 W. Little York Rd., • Katy, TX 77449  
 (281) 858-5988 • Mobile: (713) 283-4528

Texas State Drinking Water Corp.  
 P.O. Box 755  
 Brookshire, Texas 77423

July 14, 2016

**Water Report-TCEQ Lead and Copper**  
**Skylakes WSC**  
**PWS# 2370014**

| Sample # | I.D.                   | Date       | Time  | Lead mg/L | Copper mg/L | Analysis Date    | Analyst | Method    |
|----------|------------------------|------------|-------|-----------|-------------|------------------|---------|-----------|
| D16.2247 | LCR008-15542 Kittyhawk | 06/13/2016 | 06:00 | <0.001    | 0.2669      | 6/20/2016 14:09  | A&B***  | EPA 200.8 |
| D16.2248 | LCR009-15502 Kittyhawk | 06/13/2016 | 05:30 | <0.001    | 0.1340      | 6/20/2016 14:12  | A&B***  | EPA 200.8 |
| D16.2249 | LCR010-32218 Robin     | 06/13/2016 | 06:00 | <0.001    | 0.0419      | 6/20/2016 14:14  | A&B***  | EPA 200.8 |
| D16.2250 | LCR012-15633 Sandtrap  | 06/13/2016 | 06:00 | <0.001    | 0.4147      | 6/20/2016 14:17  | A&B***  | EPA 200.8 |
| D16.2251 | LCR016-32227 Skyway    | 06/13/2016 | 06:00 | <0.001    | 0.2412      | 6/20/2016 14:19  | A&B***  | EPA 200.8 |
| D16.2252 | LCR001-32110 Whitewing | 06/13/2016 | 06:00 | <0.001    | 0.0221      | 6/20/2016 14:21  | A&B***  | EPA 200.8 |
| D16.2253 | LCR003-32226 Whitewing | 06/13/2016 | 07:30 | <0.001    | 0.0157      | 6/20/2016 14:24  | A&B***  | EPA 200.8 |
| D16.2254 | LCR004-15631 Kittyhawk | 06/13/2016 | 06:30 | <0.001    | 0.0167      | 6/20/2016 14:26  | A&B***  | EPA 200.8 |
| D16.2255 | LCR005-32106 Bunker    | 06/13/2016 | 07:15 | 0.0021    | 0.0112      | 6/20/2016 14:36  | A&B***  | EPA 200.8 |
| D16.2256 | LCR006-32203 Whitewing | 06/13/2016 | 06:28 | 0.0018    | 0.2060      | 6/20/20196 14:38 | A&B***  | EPA 200.8 |

  
 Rhonda J. Scrogin

Quality Manager  
 R&C Joy Inc.

\*Regulatory Limit for Lead is 0.015 mg/L

\*\*Regulatory Limit for Copper is 1.3 mg/L

\*\*\*A&B is the subcontracted lab-See attached report.





19020 W. Little York Rd., • Katy, TX 77449  
 (281) 858-5988 • Mobile: (713) 283-4528

Texas State Drinking Water Corp.  
 P.O. Box 755  
 Brookshire, Texas 77423

July 14, 2016

Page 1 of 1

**Water Report-TCEQ Lead and Copper  
 Skylakes WSC  
 PWS# 2370014**

| Sample # | I.D.                     | Date       | Time  | Lead<br>mg/L | Copper<br>mg/L | Analysis Date   | Analyst | Method    |
|----------|--------------------------|------------|-------|--------------|----------------|-----------------|---------|-----------|
| D16.1864 | EP001-Water Plant #1 GST | 05/19/2016 | 15:10 | <0.001       | 0.0025         | 5/26/2016 18:32 | A&B***  | EPA 200.8 |
| D16.1865 | EP002-Water Plant #2 HPT | 05/19/2016 | 15:40 | 0.0010       | 0.0079         | 5/26/2016 18:35 | A&B***  | EPA 200.8 |

Rhonda J. Scrogin  
 Quality Manager  
 R&C Joy Inc.

\*Regulatory Limit for Lead is 0.015 mg/L

\*\*Regulatory Limit for Copper is 1.3 mg/L

\*\*\*A&B is the subcontracted lab-See attached report.





19020 W. Little York Rd., • Katy, TX 77449  
(281) 858-5988 • Mobile: (713) 283-4528

Texas State Drinking Water Corp.  
P.O. Box 755  
Brookshire, Texas 77423

July 15, 2016

**Water Report-TCEQ Lead and Copper**  
**Skylakes WSC**  
**PWS# 2370014**

| Sample # | I.D.            | Date       | Time  | Lead<br>mg/L | Copper<br>mg/L | Analysis Date  | Analyst | Method    |
|----------|-----------------|------------|-------|--------------|----------------|----------------|---------|-----------|
| D16.2482 | EP002-Faucet    | 06/23/2016 | 10:12 | 0.0014       | 0.0085         | 7/5/2016 18:41 | A&B***  | EPA 200.8 |
| D16.2483 | EP001-PT Faucet | 06/23/2016 | 10:35 | 0.0010       | 0.0013         | 7/5/2016 18:44 | A&B***  | EPA 200.8 |

Rhonda J. Scrogin  
Quality Manager  
R&C Joy Inc.

\*Regulatory Limit for Lead is 0.015 mg/L

\*\*Regulatory Limit for Copper is 1.3 mg/L

\*\*\*A&B is the subcontracted lab-See attached report.

ENVIRONMENTAL CONSULTING • LABORATORY • PROCESS CONTROL • PRETREATMENT