



19020 W. Little York Rd., • Katy, TX 77449
 (281) 858-5988 • Mobile: (713) 283-4528

Texas State Drinking Water Corp.
 P.O. Box 755
 Brookshire, Texas 77423

August 20, 2016

August 2016 Bacteriological Report
Skylakes Water Supply PWS ID# TX2370014

Sample Type: Routine

Sample #	Address/Location	Date	Time	Samp By	Date Rec.	Free Cl ₂ mg/L *	Total Cl ₂ mg/L *	Coliform Result
D16-3134	15542 Kittyhawk	8/2/16	13:45	M Tobola	8/2/16	1.84		Not Found



Rhonda J. Scroggin
 Quality Manager

* Field analysis performed on grab sample at the time of collection.

In this report, the accredited coliform analysis results relate only to these samples and are in compliance with TNI Standards-Certificate # T104704372

See TCEQ form(s) attached



19020 W. Little York Rd., • Katy, TX 77449
(281) 858-5988 • Mobile: (713) 283-4528

Texas State Drinking Water Corp.
P.O. Box 755
Brookshire, Texas 77423

Page 1 of 5

Water Report-WQP
Skylakes WSC- TX23700104

Sample # D16.2478
Sample ID EP001
Sample Type Grab
Date 6/23/16
Time 1030
Sampled By Client-JM

Analyses	Result	Units	Analysis Date	Analyst	Method
Alkalinity	124	mg CaCO ₃ /L	6/30/16 1319	Eastex***	SM 2320 B
Calcium	62	mg/L	7/06/16 0851	Eastex***	EPA 200.7
Conductivity	484	µmhos/cm	6/29/16 1450	Eastex***	SM 2510B
pH	7.4	STU	6/23/2016 1030	Client-JM	SM 4500-H ⁺ B; 20 th Ed.
Temperature	23.9	°C	6/23/2016 1030	Client-JM	SM 2550B

Rhonda J. Scrogin
Quality Manager
R&C Joy Inc.

***Eastex is the subcontracted lab-See attached report.

ENVIRONMENTAL CONSULTING • LABORATORY • PROCESS CONTROL • PRETREATMENT



18035 W. Little York Rd., Suite J • Katy, TX 77449
(281) 858-5988 • Mobile: (713) 283-4528

Texas State Drinking Water Corp.

P.O. Box 755

Brookshire, Texas 77423

April 12, 2016

Page 1 of 3

Water Report-Corrosion Study
Skylakes Water Supply-TX2730014

Sample # D16.1115
Sample ID EP1
Sample Type Grab
Date 3/23/16
Time 1812
Sampled By Client-JM

Analyses	Result	Units	Analysis Date	Analyst	Method
Alkalinity	140	mg CaCO ₃ /L	3/28/16 1732	Eastex**	SM 2320 B
Calcium	61.1	mg/L	3/30/16 1457	Eastex**	EPA 200.7
Conductivity	490	µmhos/cm	3/29/16 1415	Eastex**	SM 2510B
pH	7.5	STU	3/23/16 1812	Client-JM	SM 4500-H ⁺ B; 20 th Ed.
Temperature	21.0	°C	3/23/16 1812	Client-JM	SM 2550B

Ronald E. Joy

President

R&C Joy Inc.

** Eastex is the subcontracted lab-See attached report.

ENVIRONMENTAL CONSULTING • LABORATORY • PROCESS CONTROL • PRETREATMENT



19020 W. Little York Rd., • Katy, TX 77449
(281) 858-5988 • Mobile: (713) 283-4528

Texas State Drinking Water Corp.
P.O. Box 755
Brookshire, Texas 77423

July 14, 2016

Page 1 of 1

Water Report-TCEQ Lead and Copper
Skylakes WSC
PWS# 2370014

Sample #	I.D.	Date	Time	Lead mg/L	Copper mg/L	Analysis Date	Analyst	Method
D16.2247	LCR008-15542 Kittyhawk	06/13/2016	06:00	<0.001	0.2669	6/20/2016 14:09	A&B***	EPA 200.8
D16.2248	LCR009-15502 Kittyhawk	06/13/2016	05:30	<0.001	0.1340	6/20/2016 14:12	A&B***	EPA 200.8
D16.2249	LCR010-32218 Robin	06/13/2016	06:00	<0.001	0.0419	6/20/2016 14:14	A&B***	EPA 200.8
D16.2250	LCR012-15633 Sandtrap	06/13/2016	06:00	<0.001	0.4147	6/20/2016 14:17	A&B***	EPA 200.8
D16.2251	LCR016-32227 Skyway	06/13/2016	06:00	<0.001	0.2412	6/20/2016 14:19	A&B***	EPA 200.8
D16.2252	LCR001-32110 Whitewing	06/13/2016	06:00	<0.001	0.0221	6/20/2016 14:21	A&B***	EPA 200.8
D16.2253	LCR003-32226 Whitewing	06/13/2016	07:30	<0.001	0.0157	6/20/2016 14:24	A&B***	EPA 200.8
D16.2254	LCR004-15631 Kittyhawk	06/13/2016	06:30	<0.001	0.0167	6/20/2016 14:26	A&B***	EPA 200.8
D16.2255	LCR005-32106 Bunker	06/13/2016	07:15	0.0021	0.0112	6/20/2016 14:36	A&B***	EPA 200.8
D16.2256	LCR006-32203 Whitewing	06/13/2016	06:28	0.0018	0.2060	6/20/20196 14:38	A&B***	EPA 200.8


Rhonda J. Scroggin
Quality Manager
R&C Joy Inc.

*Regulatory Limit for Lead is 0.015 mg/L

**Regulatory Limit for Copper is 1.3 mg/L

***A&B is the subcontracted lab-See attached report.

ENVIRONMENTAL CONSULTING • LABORATORY • PROCESS CONTROL • PRETREATMENT



19020 W. Little York Rd., • Katy, TX 77449
(281) 858-5988 • Mobile: (713) 283-4528

Texas State Drinking Water Corp.
P.O. Box 755
Brookshire, Texas 77423

July 14, 2016

Page 1 of 1

Water Report-TCEQ Lead and Copper
Skylakes WSC
PWS# 2370014

Sample #	I.D.	Date	Time	Lead mg/L	Copper mg/L	Analysis Date	Analyst	Method
D16.1864	EP001-Water Plant #1 GST	05/19/2016	15:10	<0.001	0.0025	5/26/2016 18:32	A&B***	EPA 200.8
D16.1865	EP002-Water Plant #2 HPT	05/19/2016	15:40	0.0010	0.0079	5/26/2016 18:35	A&B***	EPA 200.8


Rhonda J. Scrogin
Quality Manager
R&C Joy Inc.

*Regulatory Limit for Lead is 0.015 mg/L

**Regulatory Limit for Copper is 1.3 mg/L

***A&B is the subcontracted lab-See attached report.

ENVIRONMENTAL CONSULTING • LABORATORY • PROCESS CONTROL • PRETREATMENT